

MIAMI-DADE COUNTY
BUILDING CODE COMPLIANCE OFFICE (BCCO)
PRODUCT CONTROL DIVISION

MIAMI-DADE COUNTY, FLORIDA
METRO-DOMESTIC LAGER BUILDING
140 WEST FLAGLER STREET, SUITE 1603
MIAMI, FLORIDA 33130-1563
(305) 375-2961 FAX (305) 375-2968

NOTICE OF ACCEPTANCE (NOA)

Sunshine Windows Manufacturing, Inc.
1745 W. 33rd Place
Hialeah, FL 33012

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by Miami-Dade County Product Control Division and accepted by the Board of Rules and Regulations (BORR) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Division (in Miami Dade County) and the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for compliance with applicable building codes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may reserve the right to revoke, modify, or suspend the use of such product or material within their jurisdiction. BORR reserves the right to revoke this NOA if it is determined by Miami-Dade County Product Control Division that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: Series 4320 Aluminum Fixed Window

APPROVAL DOCUMENT: Drawing No. PW-99-01, titled "Series 4320 Aluminum Fixed Window", sheets 1 through 3 of 3, dated 9/24/00, prepared by the Francisco Hernandez P.E. Structural Engineering, signed and sealed by Francisco Hernandez, P.E., bearing the Miami-Dade County Product Control Renewal stamp with the Notice of Acceptance number and expiration date by the Miami-Dade County Product Control Division.

MISSILE IMPACT RATING: None

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL: If this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION: If this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and manufacturing of the product or process. Misuse of this NOA as an endorsement of any product for sale, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISING: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official. This NOA renews NOA # 00-0512.04 and consists of this page 1, evidence page(s), as well as approval document mentioned above.

The submitted documentation was reviewed by Manuel Perez, P.E.



Manuel Perez

NOA No. 05-0529.02
Expiration Date: September 16, 2008
Approval Date: September 25, 2005
Page 1