

DAB Door Company, Inc.

ACCEPTANCE NO: 01-0626.01

APPROVED: OCT 0 4 2001

EXPIRES: OCT 0 4 2006

NOTICE OF ACCEPTANCE: SPECIFIC CONDITIONS

1. SCOPE

1.1 This approves a Sectional Steel Door as described in Section 2 of this Notice of Acceptance. And it is to comply with the South Florida Building Code, 1994 Edition for Miami-Dade County (SFBC) for the locations where the pressure requirements, as determined by SFBC Chapter 23, do not exceed the design pressure rating values indicated in the approved drawings.

2. PRODUCT DESCRIPTION

2.1 The DAB 9' wide Sectional Door and its components shall be constructed in strict compliance with the following documents: Drawing No. 01-19, titled "Sectional Residential Garage Door", prepared by A-I-F Corporation, dated 04/06/01 with latest revision on 08/30/04, Sheet 1 to 3. It bears the Miami-Dade Product Control Approval stamp with the Notice of Acceptance number and approval date by Miami-Dade Product Control Division. These documents shall hereinafter be referred to as the approved drawings.

3. LIMITATIONS

3.1 Units with dimensions equal to or smaller than those shown on the approved drawings shall qualify and approval, as long as all components are exactly as described in this approval.

3.2 This approval requires the manufacturer to do testing of all coils used to fabricate door panels under the of Acceptance. A minimum of 2 specimens shall be cut from each coil and tensile tested according to A E-8 by a Dade County Approved Laboratory selected and paid by the manufacturer. Every 2 months, 4 year the manufacturer shall mail to this office a copy of the Test Reports with confirmation that the specimens were selected from coils at the manufacturer's production facilities. And a notarized statement from the manufacturer that only coils with yield strength of 39,000 PSI or more shall be used to make door panel Dade County under this Notice of Acceptance.

4. INSTALLATION

4.1 The Sectional Door and its components shall be constructed in strict compliance with the approved drawings.

4.2 The installation of this door does not require a Hurricane Protection System

5. LABELING

5.1 Each door shall bear a permanent label with the manufacturer's name or logo, city, state and the following statement: "Miami-Dade County Product Control Approved"

6. BUILDING PERMIT

6.1 Building Permit shall be accompanied by copies of the following:

6.1.1 This Notice of Acceptance, including two copies of the approved drawings as identified in Section 2 of this Notice of Acceptance.

6.1.2 Any other document required by the Building Official or the SFBC in order to properly evaluate the installation of this system.

Candido Font, PE, Sr. Product Control E:
Product Control Division